



防爆合格证

证号: GYJ16.1233

由 德国PEPPERL+FUCHS有限公司

制造的产品:

(地址: Lillienthalstrasse 200, 68307 Mannheim, Germany)

名称 隔离式安全栅

型号规格 KFD2-UFa-Exb.c 系列、KFU8-UFa-Exb.c 系列

防爆标志 [Ex ia Ga] IIC

产品标准 /

图样编号 /

经图样及技术文件的审查和样品检验, 确认上述产品符合 GB 3836.1-2010、GB 3836.4-2010、GB 3836.20-2010 标准, 特颁发此证。

本证书有效期: 2016年4月26日至2021年4月25日

备注 1. 安全使用注意事项见本证书附件。
2. 型号规格说明见本证书附件。
3. 本安电气参数见本证书附件。

站长

国家级仪器仪表防爆安全监督检验站

颁发日期二〇一六年四月二十六日

本证书仅对与认可文件和样品一致的产品有效。

地址: 上海市漕宝路103号
邮编: 200233

网址: www.nepsi.org.cn
Email: info@nepsi.org.cn

电话: +86 21 64368180
传真: +86 21 64844580



EXPLOSION PROTECTION CERTIFICATE OF CONFORMITY

Cert NO.GYJ16.1233

This is to certify that the product

Isolated Barrier

manufactured by PEPPERL+FUCHS GmbH

(Address:Lilienthalstrasse 200, 68307 Mannheim, Germany)

which model is KFD2-UF~~a~~-Ex~~b~~ · ~~c~~ Series, KFU8-UF~~a~~-Ex~~b~~ · ~~c~~ Series

Ex marking [Ex ia Ga] II C

product standard /

drawing number /

has been inspected and certified by NEPSI, and that it conforms
to GB 3836.1-2010,GB 3836.4-2010,GB 3836.20-2010

This Approval shall remain in force until 2021.04.25

Remarks 1.Conditions for safe use are specified in the attachment to this certificate.
2.Model designation is specified in the attachment to this certificate.
3.Intrinsic safety parameters specified in the attachment to this certificate.

Director



National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation

Issued Date 2016.04.26

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road
Shanghai 200233, China

<http://www.nepsi.org.cn>
Email: info@nepsi.org.cn

Tel: +86 21 64368180
Fax: +86 21 64844580

国家级仪器仪表防爆安全监督检验站

National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation

(GYJ16.1233)

(Attachment I)

GYJ16.1233防爆合格证附件 I

德国PEPPERL+FUCHS有限公司生产的KFD2 - UF_a - Ex_b · _c系列和KFU8 - UF_a - Ex_b · _c系列隔离式安全栅，经国家级仪器仪表防爆安全监督检验站（NEPSI）检验，符合下列标准规定的要求：

GB3836.1 - 2010 爆炸性环境 第1部分：设备 通用要求

GB3836.4 - 2010 爆炸性环境 第4部分：由本质安全型“i”保护的的设备

GB3836.20 - 2010 爆炸性环境 第20部分：设备保护级别（EPL）为Ga级的设备
产品防爆标志为[Ex ia Ga]II C，防爆合格证号为GYJ16.1233。

一、产品使用注意事项

1. 证书包括的产品规格如下：

KFD2 - UFT - Ex2.D_c

KFU8 - UFT - Ex2.D_c

KFD2 - UFC - Ex1.D_c

KFU8 - UFC - Ex1.D_c

_c 代码：版本信息，不影响防爆性能。

2. 隔离式安全栅必须安装在安全场所，使用环境温度范围为 - 20℃ ~ +60℃。

3. 隔离式安全栅非本安端子的电气参数：

端子代号	正常工作电气参数	最高电压 U _m
23-24	20V~30Vd.c. (KFD2)	40V
	20V~90Vd.c. (KFU8) 或 48V~250Va.c.	250V
PR: 1, 2	20V~30Vd.c. (KFD2)	40V
7-8	0/4~20(mA) 最大电阻: 650Ω	40V
10-11-12 16-17-18	AC: 250V/2A/500W DC: 40V/2A/80W	250V
19-20 / 20-21	/	40V
13-14 / 14-15	/	40V
RS232接口	/	40V
PR: 3, 5	/	40V
PR: 4	/	40V

4. 变压器隔离式安全栅本安端子（端子：1-3 / 4-6）的电气参数：

连接方式	最高输出电压 U _o (V)	最大输出电流 I _o (mA)	最大输出功率 P _o (mW)	最大内部等效参数	
				Ci (μ F)	Li (mH)
单通路	10.1	13.5	34	0	0
双通路并联	10.1	27	68	0	0

连接方式	气体组别	最大外部分布参数	
		Co (μ F)	Lo (mH)
单通路	IIC	2.87	195
	IIB	19.4	730
	IIA	93	1000
双通路 并联	IIC	2.87	46
	IIB	19.4	170
	IIA	93	380

连接方式	气体组别	最大外部集中参数	
		Co (μ F)	Lo (mH)
单通路	IIC	0.4	5
	IIB	1.5	10
	IIA	3.0	20
双通路 并联	IIC	0.4	5
	IIB	1.5	10
	IIA	3.0	20

5. 产品的安装、使用和维护应同时遵守产品说明书、GB3836.13 - 2013 “爆炸性环境第13部分：设备的修理、检修、修复和改造”、GB3836.15 - 2000 “爆炸性气体环境用电气设备第15部分：危险场所电气安装（煤矿除外）”、GB3836.16 - 2006 “爆炸性气体环境用电气设备第16部分：电气装置的检查和维护（煤矿除外）”、GB3836.18 - 2010 “爆炸性环境第18部分：本质安全系统”和GB50257 - 2014 “电气装置安装工程爆炸和火灾危险环境电气装置施工及验收规范”的有关规定。

二、制造厂责任

1. 产品制造厂必须将上述使用注意事项纳入隔离式安全栅使用说明书。
2. 制造厂必须严格按照NEPSI认可的文件资料生产：

图纸代号	版本号/签署日期	备注
16-532TV - 00C	2014.02.20	-
16-532TV - 01B	2009.07.30	-
16-532TV - 02	2006.09.05	-
16-532TV - 03B	2009.07.30	-
16-532TV - 04	2006.04.19	-
16-532TV - 05B	2009.07.30	-
16-532TV - 06	2006.05.09	-
16-532TV - 07	2006.06.30	-
16-532TV - 09C	2014.01.21	-
16-532TV - 10C	2014.01.21	-
16-532TV - 47C	2012.07.11	-
16-532TV - 47D	2014.02.20	-

3. 产品铭牌中至少应包括下列内容：
- (1) NEPSI认可标志（见防爆合格证书）
 - (2) 产品防爆标志
 - (3) 防爆合格证号
 - (4) 电气参数或说明

国家级仪器仪表防爆安全监督检验站
二〇一六年四月二十六日



国家级仪器仪表防爆安全监督检验站

National Supervision and Inspection Centre for Explosion Protection and Safety of Instrumentation

(GYJ16.1233)

(Attachment I)

Attachment I (Translation)

Isolated Barrier type KFD2-UFC-Ex₂D₂ and KFU8-UFC-Ex₂D₂, manufactured by PEPPERL+FUCHS GmbH, has been approved by National Supervision and Inspection Center for Explosion Protection and Safety of Instrumentation (NEPSI) in accordance with the following standards:

GB3836.1-2010 Electrical atmospheres – Part 1: Equipment – General requirements

GB3836.4-2010 Electrical atmospheres – Part 4: Equipment protection by Intrinsic safety “i”

GB3836.20-2010 Electrical atmospheres – Part 20: Equipment with equipment protection level (EPL) Ga

The isolated barrier is approved with explosion marking of [Ex ia Ga] II C. The certificate number is GYJ16.1233.

1. SPECIAL REQUIREMENTS

1.1 The types to this certificate are as below:

KFD2-UFT-Ex₂D₂ KFU8-UFT-Ex₂D₂

KFD2-UFC-Ex₁D₂ KFU8-UFC-Ex₁D₂

codes: Versions of the modules, no affection intrinsic safety.

1.2 The isolated barrier must be located in a non-hazardous area, the permissible maximum ambient temperature range is -20°C~+60°C.

1.3 Electrical parameters at the terminals for the non-intrinsically safe circuits:

Terminals	Normal Electrical data	Max. voltage (Um)
23-24	20V~30Vd.c. (KFD2)	40V
	20V~90Vd.c. (KFU8) or 48V~250Va.c.	250V
PR: 1, 2	20V~30Vd.c. (KFD2)	40V
7-8	0/4~20(mA) R Max: 650Ω	40V
10-11-12 16-17-18	AC: 250V/2A/500W DC: 40V/2A/80W	250V
19-20/20-21	/	40V
13-14/14-15	/	40V
RS232 interface	/	40V
PR: 3, 5	/	40V
PR: 4	/	40V

1.4 Electrical parameters at terminals (1-3 or 4-6) for the intrinsically safe circuits:

Connection	Max.output voltage U _o (V)	Max.output current I _o (mA)	Max.output power P _o (mW)	Maximum internal parameters	
				C _i (μF)	L _i (mH)
Single channel	10.1	13.5	34	0	0
Channel parallel	10.1	27	68	0	0

Connection	Gas groups	Maximum external parameters (Without lumped parameters)	
		Co (μF)	Lo (mH)
Single channel	II C	2.87	195
	II B	19.4	730
	II A	93	1000
Channel parallel	II C	2.87	46
	II B	19.4	170
	II A	93	350

Connection	Gas groups	Maximum external parameters (With lumped parameters)	
		Co (μF)	Lo (mH)
Single channel	II C	0.4	5
	II B	1.5	10
	II A	3.0	20
Channel parallel	II C	0.4	5
	II B	1.5	10
	II A	3.0	20

1.5 During installation, operation and maintenance, users shall comply with the relevant requirements of the product instruction manual, GB3836.13-2013 "Explosive atmospheres-Part 13: Equipment repair, overhaul and reclamation", GB3836.15-2000 "Electrical apparatus for explosive gas atmospheres Part 15: Electrical installations in hazardous areas (other than mines)", GB3836.16-2006 "Electrical apparatus for explosive gas atmospheres Part 16: Inspection and maintenance of electrical installation (other than mines)", GB3836.18-2010 Explosive atmospheres-Part 18:Intrinsically safe system and GB50257-2014 "Code for construction and acceptance of electric device for explosion atmospheres and fire hazard electrical equipment installation engineering".

2. MANUFACTURER'S RESPONSIBILITY

2.1 The instruction manual shall include all the clauses mentioned above.

2.2 The manufacturer shall exactly conform to the documents approved by NEPSI as following.

Drawing No	Rev./Dated	Remark
16-532TV-00C	2014.02.20	-
16-532TV-01B	2009.07.30	-
16-532TV-02	2006.09.05	-
16-532TV-03B	2009.07.30	-
16-532TV-04	2006.04.19	-
16-532TV-05B	2009.07.30	-
16-532TV-06	2006.05.09	-
16-532TV-07	2006.06.30	-
16-532TV-09C	2014.01.21	-
16-532TV-10C	2014.01.21	-
16-532TV-47C	2012.07.11	-
16-532TV-47D	2014.02.20	-

2.3 The nameplate shall include the following:

2.3.1 Identification of NEPSI.

2.3.2 Marking and Certificate No.

2.3.3 Certificate No.

2.3.4 Electrical parameters or specification

National Supervision and Inspection Centre
For Explosion Protection and Safety of Instrumentation

April 26, 2016